

PV Enhanced Concentrating Solar Power (CSP) for Base Load Power Generation in South Africa

Christoph A. Pan

Solar Thermal Energy Research Group (STERG),
University of Stellenbosch

Contents





- Motivation
- Objective
- Methodology
- PV power plant simulation
- Central receiver with molten salt TES
- CSP vs. CSP/PV
- Conclusion
- References

Motivation

Constrained fossil power system


- electricity generation highly dependant on coal
- average age of power plant fleet: 34 years
- load shedding of up to 4 GW
- need for supply security



Motivation

Solar resource in South Africa

- GHI up to 2,300 kWh/m²a (Seville 1,800 kWh/m²a)
- DNI up to 3,200 kWh/m²a (Seville 2,100 kWh/m²a)




source: SolarGIS 2014a,b

Objective


Research question

- Can the advantages of cheap PV and dispatchability of CSP with thermal energy storage (TES) be combined to supply 100 MW constant base load capacity in South Africa?



Methodology

- power plant simulation in SAM (NREL)
- fixed parameters for PV (one option)
- varying solar multiple (SM) and TES size for CSP (multiple options)
- simulated power plants:




- comparison of plant performance, capacity factor and load profiles


PV power plant simulation




Item	Unit	Value
total module capacity	MW _p	110
total inverter capacity	MW _{AC}	100.3
annual energy	GWh	223.6
capacity factor	%	23.2
specific yield	kWh _{AC} /kW _{DC}	2,033
performance ratio	%	84.0



monthly PV electricity production



hourly load profile over a year





Central receiver with molten salt TES



Simulated configurations

Item	Unit	Value											
Turbine capacity, gross	MW _e	115											
Turbine capacity, net	MW _e	100											
design HTF inlet temperature	°C	565											
design HTF outlet temperature	°C	290											
cycle gross efficiency	%	42											
steam generator thermal power	MW _{th}	273.8											
heat transfer fluid	-	Salt (60% NaNO ₃ , 40% KNO ₃)											
TES full load hours	h	14				16							
solar multiple	-	1.5	2	2.5	3	3.5	4	1.5	2	2.5	3	3.5	4
TES full load hours	h	18				20							
solar multiple	-	1.5	2	2.5	3	3.5	4	1.5	2	2.5	3	3.5	4



Control “strategy”

- No possibility to provide hourly load profile of PV in SAM to determine CSP demand
- Very simplistic implementation:
 - TES dispatch control with 24 h representing an average day every month
 - based on average monthly PV generation profile
 - CSP fills the gap to 100 MW
- Huge improvement possible but sufficient for this study

	12am	1am	2am	3am	4am	5am	6am	7am	8am	9am	10am	11am	12pm	1pm	2pm	3pm	4pm	5pm	6pm	7pm	8pm	9pm	10pm	11pm	
Jan	9	9	9	9	9	9	9	9	9	8	7	5	4	3	3	3	4	5	6	8	9	9	9	9	9
Feb	9	9	9	9	9	9	9	9	9	8	7	5	4	3	3	3	3	4	6	8	9	9	9	9	9
Mar	9	9	9	9	9	9	9	9	9	8	6	5	4	3	3	3	4	5	6	8	9	9	9	9	9
Apr	9	9	9	9	9	9	9	9	9	8	6	5	3	3	3	3	4	5	6	8	9	9	9	9	9
May	9	9	9	9	9	9	9	9	9	6	4	3	2	2	3	3	5	7	9	9	9	9	9	9	9
Jun	9	9	9	9	9	9	9	9	9	6	5	3	3	2	3	3	5	7	9	9	9	9	9	9	9
Jul	9	9	9	9	9	9	9	9	9	6	5	3	2	2	2	3	4	6	9	9	9	9	9	9	9
Aug	9	9	9	9	9	9	9	9	9	6	4	3	2	2	2	3	4	6	8	9	9	9	9	9	9
Sep	9	9	9	9	9	9	9	9	9	8	6	4	3	2	2	2	3	4	6	8	9	9	9	9	9
Oct	9	9	9	9	9	9	9	9	9	7	6	4	3	3	2	3	3	5	7	8	9	9	9	9	9
Nov	9	9	9	9	9	9	9	9	9	8	6	4	3	3	3	3	4	5	7	8	9	9	9	9	9
Dec	9	9	9	9	9	9	9	9	9	8	6	5	4	3	3	3	4	5	6	8	9	9	9	9	9


TES dispatch control matrix

Period	Turbine output fraction [%]
2	20
3	30
4	40
5	50
6	60
7	70
8	80
9	95

CSP vs. CSP/PV



Net electricity generation




higher electricity yield with small **CSP/PV** than with larger **standalone CSP**

CSP vs. CSP/PV


Capacity factors

CSP



CSP/PV

*based on 100 MW (actually 200 MW installed)




CSP vs. CSP/PV




Load profiles


CSP



CSP/PV



solar resource




CSP vs. CSP/PV



Hourly load profile over a year


solar field is too small to charge large storage which leads to several turbine stops

CSP - SM 3, 20 h TES





less turbine stops due to additional PV

CSP/PV - SM 3, 20 h TES



CSP vs. CSP/PV

Probability distribution




Conclusion



PV enhanced CSP plants can provide base load capacity for the SA grid

- Higher electricity yields compared to standalone CSP
- High capacity factors (>90 %)
- Reduced system size and therefore costs
- Constant power output for base load generation
- Improved control strategy leads to even better results



References

- Eskom. 2015a. Integrated Report 2015. Available at: <http://www.eskom.co.za/IR2015/Documents/EskomIR2015single.pdf> [Accessed August 14, 2015].
- Eskom. 2015b. *System Status Presentation*. Media Presentation (January 15, 2015) by Tshediso Matona, Eskom Holding.
- IEA (International Energy Agency). 2015. *Electricity & Heat Statistics South Africa*. Paris, France. Available at: <http://www.iea.org/statistics/statisticssearch/> [Accessed March 18, 2015].
- SolarGIS. 2014a. *SolarGIS Global Horizontal Irradiation Map for South Africa, Lesotho and Swaziland*. GeoModel Solar. Available at: http://www.sauran.net/Docs/SolarGIS_GHI_South_Africa_width15cm_300dpi.png [Accessed May 04, 2015].
- SolarGIS. 2014b. *SolarGIS Direct Normal Irradiation Map for South Africa, Lesotho and Swaziland*. GeoModel Solar. Available at: http://www.sauran.net/Docs/SolarGIS_DNI_South_Africa_width15cm_300dpi.png [Accessed May 04, 2015].

Thank you for your attention!

ACKNOWLEDGEMENTS:

Supervision of Prof. Frank Dinter

CONTACT DETAILS:

Christoph Adrian Pan
Solar Thermal Energy Research
Group (STERG)
Stellenbosch University
South Africa

20559720@sun.ac.za
+27 (0)21 808 4016

visit us: concentrating.sun.ac.za